

# Cannot send email notification from Alarm Monitoring, error "Failed send 1 of 1 messages to Global Output server"

Last Modified on 10/06/2022 4:15 am EDT

## Symptom

Cannot sent email notification from Alarm Monitoring, with the following error shown in Alarm Monitoring:

Failed send 1 of 1 messages to Global Output server, RPC server is unavailable.

## Resolution

Verify GOS server workstation name is correct in **System Administration > Administration > Global Output Devices > Workstation**.

Make sure the GOS server is running on the workstation.

## Applies To

OnGuard (All versions)

## Additional Information

---