

"Day Contact Restore" alarms coming in to Alarm Monitoring on NGP panels

Last Modified on 10/06/2022 4:15 am EDT

Symptom

"Day Contact Restore" alarms come into Alarm Monitoring on NGP panels

Resolution

This was found because the EOL configuration for the REX input was wired incorrectly. Refer to the *NGP Hardware Installation Guide* for more information.

Applies To

OnGuard (all versions)

Additional Information
