

# DataConduit: the EventText property of Lnl\_SecurityEvent is not loaded

Last Modified on 10/06/2022 4:17 am EDT

## Symptom

The EventText property of Lnl\_SecurityEvent is always empty. I want it to contain the event's associated text or event parameter.

## Resolution

In order to retrieve an event's associated text, use the SerialNumber property to lookup the corresponding Lnl\_LoggedEvent as follows:

```
SELECT * FROM Lnl_LoggedEvent WHERE SerialNumber = <value of SerialNumber property from received event>
```

The Lnl\_LoggedEvent also has an EventText property which contains the associated text.

## Applies To

OnGuard (All versions)

## Additional Information

It might be advantageous to cache the event subtype definitions (Lnl\_EventSubtypeDefinition) and then check the SupportParameters property to see if an event has a parameter before loading the corresponding Lnl\_LoggedEvent.

---