

# Unable to pulse elevator outputs through DataConduit

Last Modified on 10/06/2022 4:17 am EDT

## Symptom

Elevator outputs do not pulse when attempted through DataConduit. However, other non-elevator outputs can be pulsed through DataConduit.

## Resolution

DataConduit currently does not support the ability to pulse elevator outputs. There are no work-arounds available to pulse elevator hardware through DataConduit.

## Applies To

OnGuard (All versions)

## Additional Information

---