

# In OnGuard Monitor, still receiving alarms from all devices, even if the device is not part of the same monitor zone

Last Modified on 10/06/2022 4:18 am EDT

## Symptom

In OnGuard Monitor, user receives alarms from all available devices even if there are no devices assigned to the chosen monitor zone.

## Resolution

Update the OnGuard Monitor module to version 1.2.187 or later.

## Applies To

OnGuard Monitor 1.0.117 (base version for OnGuard 7.4), OnGuard Monitor 1.1.126 (base version for OnGuard 7.5).

## Additional Information

Copyright © 2022 Carrier. All rights reserved.

---