Low Battery and Tamper Reporting for Schlage Wireless Locks (OG-18069)

Last Modified on 10/06/2022 4:20 am ED

Problem Overview

Low Battery and Tamper Reporting for Schlage Wireless Locks (OG-18069)

Detailed Description

To enable low battery and tamper reporting for Schlage wireless locks, the **Keypad Type** on the reader tab must be set to **LNL-2020 w/ Tamper**. This setting can also be used with the Schlage WRI wireless reader interface, but this will disable keypad support.

Applies To

OnGuard 2008 (6.0.148) OnGuard 2008 Plus (6.1.222)

Additional Information

None