

LNL-2210 Power Fail Input error

Last Modified on 10/06/2022 4:20 am EDT

Symptom

LNL-2210 Power Fail Input error.

The LNL-2210 shows Power Fail Input in Alarm Monitoring, but the LNL-2210 does not have a jumper for Power Fail Input.

Resolution

Install OnGuard version 6.4.500 TU1 or newer. If using Firmware 1.188 do a Database download to the panel to clear the message.

Applies To

OnGuard 2010 (6.4.500)

Additional Information
